



FIRE HYDRANT-STANDARD DETAIL

NOT TO SCALE

NOTES:

1. THE THRUST BLOCKING MUST NOT COVER THE HYDRANT DRAIN HOLE.
2. FIRE HYDRANT COLOR TO BE RED WITH WHITE TOP AND CAPS COLORED CODED TO MATCH FLOW, SEE TABLE THIS DETAIL.
3. HYDRANT DRAINS SHALL NOT BE CONNECTED WITHIN 10FT OF SEWER SYSTEMS.

CAP COLOR CODING:

500 gpm - 999 gpm	Safety Orange
1000 gpm - 1499 gpm	Safety Green
>1600 gpm	Safety Blue



REVISIONS

DATE	BY	DESCRIPTION
9/29/05	CKC	ADDED COLOR CODING
9/29/05	CKC	CHANGED HYDRANT TYPE

PREPARED BY:

The City of North Augusta

• ENGINEERING DEPARTMENT •

P.O. BOX 6400 400 E. BUENA VISTA AVENUE
NORTH AUGUSTA S.C. 29861
(803) 441-4223

DWG. NO.

4.01